

7 YEARS WARRANTY

IP 65

RoHS Compliant




# ALBATROSS 1.5 INDUSTRIAL LUMINAIRES


## INSTALLATION GUIDE

READ THE INSTRUCTIONS CAREFULLY BEFORE STARTING

### INSIDE THE BOX




Surface mounting



Suspended mounting

### NEEDED FOR MOUNTING


#### Surface mounting




#### Suspended mounting




### SURFACE MOUNTING



### SUSPENDED MOUNTING



TYPE	Surface mounting			Suspended mounting		
	L, mm	H, mm	W, mm	L, mm	H, mm	W, mm
50 W standard / DALI / 1-10V	350	297	56	280	297	56
100 W standard / DALI / 1-10V	370	556	62	300	556	62
150 W standard / DALI / 1-10V	900	297	56	830	297	56
150 W SENSOR	1006	297	63	971	297	63
200 W standard / DALI / 1-10V	650	556	64	580	556	64
200 W SENSOR	756	556	68	721	556	68
300 W standard / DALI / 1-10V	1095	556	66	1025	556	66
300 W SENSOR	1201	556	68	1166	556	68



## WARNING

**! Turn power off before inspection, installation or removal.**

- Properly ground electrical enclosure.
- Perform installation in dry location only.
- Luminaire may fall down if not installed properly.
- Avoid direct eye exposure to the light source while it is on.
- For indoor use only.
- Do not operate luminaire with damaged parts.
- To prevent wiring damage or abrasion, do not expose wiring to edges of sheet metal or other sharp objects.
- The manufacturer shall not be liable for any damage resulting from inappropriate modifications to the luminaire or faulty installation.

*If you have any questions, contact the manufacturer.*

7 YEARS WARRANTY

IP 65

RoHS Compliant

CE

RoHS Compliant

F


# ALBATROSS 1.5 INDUSTRIAL LUMINAIRES

## INSTALLATION GUIDE


### 1. SURFACE MOUNTING




1




2 VERSIONS WITH SENSOR ONLY




3 VERSIONS WITH SENSOR ONLY




4 SCREWING



5



6



7 [Connection scheme on page 4](#)

7 YEARS WARRANTY

IP 65

RoHS Compliant

CE


F

# ALBATROSS 1.5 INDUSTRIAL LUMINAIRES



## INSTALLATION GUIDE

### 1.2 FLOODLIGHT MOUNTING\*






\*Only available for: 50W and 100W luminaires

ACCESSORIES	NEED FOR MOUNTING
<ul style="list-style-type: none"> <li>• BWLP-SA-1-FKIT</li> <li>• BWLP-SA-2-FKIT</li> </ul>	

### DIMENSIONS

	
50W	100W

### MOUNTING

© 2023, All rights reserved BaltLED, UAB. Specifications are subject to change without notice.

7 YEARS WARRANTY

IP 65

RoHS Compliant

CE


WEEE

F


# ALBATROSS 1.5 INDUSTRIAL LUMINAIRES

## INSTALLATION GUIDE


### 2. SUSPENDED MOUNTING



1




2



3


Connection scheme on the right

#### STANDARD



L  
N  
PE

#### DALI



L  
N  
PE



DA +  
DA -

#### SENSOR



L  
N  
PE

SENSOR

SENSOR

### QUANTITY OF LUMINAIRES PER CIRCUIT BREAKER

	LUMINAIRE QTY PER	
	25A	16A
	TYPE C CIRCUIT BREAKER	
50W luminaires	112	72
100W luminaires	56	36
150W luminaires	37	24
200W luminaires	28	18
300W luminaires	19	12

# ALBATROSS 1.5 INDUSTRIAL LUMINAIRES

## INSTALLATION GUIDE MOTION SENSOR (PRESET)




With sufficient ambient lux level, light keeps off even when motion is detected.



Light is on when sensor detects the motion and the ambient lux level is insufficient



When no more motion is detected, the light dims entering standby mode after hold time.



The lights turns off automatically after standby mode.

## SET-UP CONFIGURATIONS

### 1. Detection area

This determines the effective range of the motion detector.

- I – 100 %
- II – 75 %
- III – 50 %
- IV – 10 %



	1	2	
I	●	●	100 %
II	●	○	75 %
III	○	●	50 %
IV	○	○	10 %

### 2. Hold time

This is the minimum amount of time that the luminaire will remain at 100% light output after no motion is detected.

- I – 5 s
- II – 30 s
- III – 1 min
- IV – 5 min
- V – 10 min
- VI – 20 min
- VI – 20 min



	3	4	5	
I	●	●	●	5 s
II	○	●	●	30 s
III	●	○	●	1 min
IV	●	●	○	5 min
V	○	○	●	10 min
VI	○	●	○	20 min
VII	○	○	○	30 min

### 3. Daylight sensor

This setting determines when there is insufficient daylight for natural lighting. In disable mode luminaire will always turn on upon movement.

- I – Disable
- II – 50 lux
- III – 10 lux
- IV – 2 lux



	6	7	
I	●	●	Disable
II	●	○	50 lux
III	○	●	10 lux
IV	○	○	2 lux

### 4. Corridor function

This determines standby time that the light remains dimmed before it is completely turned off.

- I – 0 s
- II – 10 s
- III – 1 min
- IV – 5 min
- V – 10 min
- VI – 30 min
- VII – 1 h
- VIII - + ∞



	8	9	10	
I	●	●	●	0 s
II	○	●	●	10 s
III	●	○	●	1 min
IV	●	●	○	5 min
V	○	○	●	10 min
VI	○	●	○	30 min
VII	●	○	○	1 h
VIII	○	○	○	+ ∞

### 5. Standby dim level

Light can be dimmed to different levels after hold time.

- I – 10 %
- II – 20 %
- III – 30 %
- IV – 50 %



	11	12	
I	●	●	10 %
II	●	○	20 %
III	○	●	30 %
IV	○	○	50 %

## INSTALLATION GUIDE

### MOTION SENSOR (REMOTE CONTROL)

#### ROTARY SWITCH PRESET


A rotary switch is built inside the sensor for scene selection / fast programming. Total 16 channels are available:



Rotary switch preset

*Note: settings can also be changed by remote control HRC-11. The last action controls.*

#### DETECTION PATTERN



Channel	Detection range	Hold-time	Daylight sensor	Stand-by time	Stand-by dim level
0	100%	5s	Disable	10s	10%
1	100%	1min	2Lux	5 min	10%
2	100%	5min	10Lux	10min	10%
3	100%	5min	30Lux	30min	10%
4	100%	5min	10Lux	0s	Disable
5	100%	5min	30Lux	+∞	10%
6	100%	5min	Disable	+∞	30%
7	100%	10min	2Lux	10min	10%
8	100%	10min	10Lux	30min	10%
9	100%	10min	30Lux	+∞	10%
A	100%	10min	Disable	+∞	30%
B	75%	10min	30Lux	+∞	10%
C	50%	10min	10Lux	+∞	10%
D	100%	30min	50Lux	+∞	10%
E	100%	30min	Disable	+∞	30%
F	100%	5s	2Lux	10s	10%

## SETTINGS



#### Permanent ON/OFF function

Press button "ON/OFF" to select permanent ON or permanent OFF mode.

- Press button "AUTO", "RESET" to quit this mode.
- The mode will change to AUTO Mode after power failure.



#### Reset Settings

Press button "RESET", all settings go back to rotary switch settings.



#### Shift Button


Press button "Shift", the LED on the top left corner is on to indicate mode selection. All values / settings in RED are valid for 20 seconds.



#### AUTO mode

Press button "AUTO" to initiate automatic mode. The sensor starts working and all settings remain as before the light is switched ON/OFF.

*Note: "Semi-auto" function is disabled.*



# ALBATROSS 1.5 INDUSTRIAL LUMINAIRES

## INSTALLATION GUIDE MOTION SENSOR (REMOTE CONTROL)



### Power output

Press the buttons to select light output at 80% (at initial 10,000 hours) or 100%.

*Note: "Sensor off" and "Twilight" functions are disabled.*



### Brightness +/-

Press the buttons to adjust the light brightness during hold-time.



### Scene program - 1-key commissioning

1. Press button "Start" to program.
2. Select the buttons in "Detection range", "Daylight threshold", "Hold-time", "Stand-by time", "Stand-by dimming level" to set all parameters.
3. Press button "Memory" to save all the settings programmed in the remote control.
4. Press button "Apply" to set the settings to each sensor unit(s).

*For example, to set detection range 100%, daylight threshold Disable, hold-time 5min, stand-by time +∞, stand-by dimming level 30%, the steps should be: Press button "Start", button "100%", "Disable", "Shift", "5min", "Shift", "+∞", "30%", "Memory". By pointing to the sensor unit(s) and pressing "Apply", all settings are passed on the sensor(s).*

### Detection range

Press buttons in zone "Detection range" to set detection range at 100% / 75% / 50% / 10%.

### Daylight threshold

Press buttons in zone "Daylight threshold" to set daylight sensor at 2Lux / 10Lux / 50Lux / 100Lux / 300Lux / 500Lux / Disable.

*Note: To set daylight sensor at 100Lux / 300Lux / 500Lux, press "Shift" button first.*

### Ambient daylight threshold

1. Press button "Shift", the red LED starts to flash.
2. Press button "Ambient", the surrounding lux level is sampled and set as the new daylight threshold.

### Hold-time

Press buttons in zone "hold-time" to set the hold-time at 2s / 30s / 1min / 5min / 10min / 15min / 20min / 30min.

*Note: 1. To set hold-time at 30s / 5min / 15min / 30min, press "Shift" button first.*

*2. 2s is for testing purpose only, stand-by period and daylight sensor settings are disabled in this mode.*

\*To exit from Test mode, press button "RESET" or any button in "Hold-time".

### Stand-by time (corridor function)

Press buttons in zone "stand-by time" to set the stand-by period at 0s / 10s / 1min / 5min / 10min / 30min / 1h / +∞.

*Note: "0s" means on/off control; "+∞" means bi-level control, the fixture is 100% on when there is motion detected, and remains at the stand-by dimming level when no presence after motion hold-time.*

### Stand-by dimming level

Press the button in zone "stand-by dimming level" to set the stand-by dimming level at 10% / 20% / 30% / 50%.

### Auto-configuration function

All buttons in this zone are disabled.

### Dual tech G RF mode

All buttons are disabled.